







# ADDENDUM 4 - JULY 31, 2015

**Payment.** The work performed and materials furnished in accordance with this Item and measured as provided under "Measurement" will be paid at the unit price bid for "Fence Grounding." This price is full compensation for furnishing, preparing, hauling, and installing materials; and for labor, tools, equipment, and incidentals necessary to complete the work.

## TPSS Fence Grounding

8. **Description.** This Item shall govern grounding of the decorative wrought iron fence surrounding each TPSS building (3 locations), as indicated on the fence grounding details in the plans. Quantities in table are for all 3 locations.
9. **Materials.** Provide the following materials or approved equivalent (Grounding details called out on Drawing S200):

| Grounding Material  | Part Number                                  | Qty.        |
|---|--|-------------|
| Copper ground rod 5/8" x 8 feet w/clamp   |  | 6           |
| #2 green insulated copper (stranded) conductor [fence to ground rod]                                  | #2 THWN Green                                | 6 X 10 feet |
| Burndy bonding connector  | BCS-23 (Mold # B-2781)                       | 6           |
| Listed 12" Insulated Wire Rope with listed bonding connectors (each end for gate connection to fence) | By Contractor, #6AWG equivalent minimum size | 9 kits/sets |

10. **Measurement.** Measure as a lump sum, complete in place as shown on the plans.

**Payment.** The work performed and materials furnished in accordance with this Item and measured as provided under "Measurement" will be paid at the unit price bid for "Fence Grounding." This price is full compensation for furnishing, preparing, hauling, and installing materials; and for labor, tools, equipment, and incidentals necessary to complete the work.